Obtrusive Light - Compliance Report

AS/NZS 4282:2019, A3 - Medium District Brightness, Curfew
Filename: Longford Bridge_ Rev1 ObtLight
26/10/2020 11:42:33 AM

Illuminance

Maximum Allowable Value: 2 Lux

Calculations Tested (1):

Calculation Label	Test Results	Max. Illum.	
ObtrusiveLight_1_Ill_Seg1		**PASS**	0.6

Luminous Intensity (Cd) At Vertical Planes

Maximum Allowable Value: 2500 Cd

Calculations Tested (1):

Calculation Label	Test Results
ObtrusiveLight_1_Cd_Seg1	**PASS**

Upward Waste Light Ratio (UWLR)

Maximum Allowable Value: 2.0 %

Calculated UWLR: 1.7 %
Test Results: **PASS**